



RIKA Innovative Ofentechnik GmbH
AT-4563 Micheldorf, Müllerviertel 20
2025
90-CPR-07.2013

EN14785:2006		
Notified Body:	51	
Intended use:	Space heating in residential buildings without possible supply of hot water	
Name:	INDUO III PELLETT	
Description:	space heating appliances fired by wood pellets - system 3	
Height	1145 mm	
Width	855 mm	
Depth	500 mm	
Fire safety	pass	
Safety distance to combustible material	rear	100 mm
	sides	100 mm
	top	750 mm
	front	800 mm
	floor	0 mm
Emission of combustion products	pass	
CO-Emission at nominal heat output	< 0,02 %	
CO-Emission at nominal heat output	< 0,25 g/Nm ³	
Release of dangerous substances	NPD	
Surface temperature	pass	
Electrical safety	pass	
Cleanability	pass	
Durability	pass	
Mechanical resistance (to carry chimney)	NPD	
Maximum operating pressure	not applicable	
Flue gas temperature at the measuring section at nominal heat output	164 °C	
Flue gas temperature outlet at nominal heat output	189 °C	
Thermal output	pass	
Nominal- / part load heat output	10,0 kW	3,0 kW
Nominal- / part load space heat output	10,0 kW	3,0 kW
Nominal- / part load water heat get output folder path	not applicable	not applicable
Efficiency	pass	
Nominal- / part load Efficiency	91,4 %	91,5 %
recommended fuel type	wood pellets (ISO 17225-2)	
Suitability for installation to a shared flue system	yes	
Emission (addition)		
CO wood pellets	g/Nm ³	< 0,25
PM wood pellets	g/Nm ³	< 0,02
OGC wood pellets	g/Nm ³	< 0,06
NO _x wood pellets	g/Nm ³	< 0,20
Pleas read manufacturer's operating instructions carefully before installing and using the appliance!		



Innovative Ofentechnik GmbH
A-4563 Micheldorf, Müllerviertel 20
Tel.: +43 (0)7582/686-54, Fax DW. -43
www.rika.at

Signed on behalf of the manufacturer

Andreas Bloderer / product manager

Name and function

Micheldorf, 22.04.2025

Place and date of issue